



# Americans with Disabilities Act Clark County Compliance Program

## Clark County Citizen ADA Advisory Board Meeting Minutes – April 27, 2010

Bud Van Cleve  
 Wayne Yarnall

Brenda Tiefenthaler  
 Jesse Magana

Tim McVicker  
 Dave Maret

Action Items	Minutes
	1:30 Pm – Meeting Commenced
	Committee reviewed accessibility survey draft report for Daybreak Park. Survey information comments included: <ol style="list-style-type: none"> <li>1. Change ANSI code criteria for West restroom door clearances</li> <li>2. Urinal not required in restroom if same restroom has a lavatory</li> <li>3. Crosswalk required from accessible parking to restroom in East park</li> <li>4. Barrier constructed on accessible path to ADA ramp for restroom access as it is adjacent to vehicle way.</li> <li>5. Accessible paths need to be constructed to park features</li> </ol>
	Tim McVicker incorporated comments into the survey report. Note: Survey was sent to Vancouver-Clark Parks Department for inclusion into their Transition Plan
Tim McVicker	The Committee has completed all initial park surveys as requested by the Vancouver-Clark Parks Department except for La Camas lake. This park is primarily the responsibility of the City of Camas and section of the park under the Vancouver-Clark Parks department is very small. Therefore, Tim McVicker will survey this park without assistance from the Committee in order to save on time and transportation issues.
Tim McVicker	Tim McVicker stated that he will contact the Vancouver-Clark Parks Department to ascertain which parks they would like to committee to survey next.
All Members	Fairground accessibility discussion – Reminder  On May 5 <sup>th</sup> at 3:30 PM, the ADA Committee is scheduled to meet Clark County fair officials to review and discuss accessibility issues

	and concerns for the 2010 fair. The purpose of the meeting is not to re-evaluate the fair but to make suggestions on how to improve accessibility.
All Members	Next monthly meeting is May 25 1:30 Pm at the Dragonfly Café.
All Members	Meeting was adjourned at 3:00 PM

*For alternate formats, contact the Clark County ADA Compliance Office  
V(36) 397-2025 TTY(360) 397-2445 FAX (360) 397-6165  
Email - ADA@Clark.WA.Gov*